

## FUEL (JP8 LARGE QUANTITIES) (Fuel Tankers/HEMTT/PODS/Collapsible Drums)

### POSSIBLE AREAS OF CONCERN

JP8 is a DOT-flammable material and should be handled in accordance with appropriate safety guidelines.

### CHARACTERIZATION

Recycled JP8 can reduce waste of fuel and funds while protecting the environment.

### HANDLING PROCEDURES

**Step 1** Bring a copy of a memo signed by the commander to **DPW Environmental Division Hazmat** stating the quantity and that the unit does not need the excess fuel.

**Step 2** Quantities in excess of 500 gallons require testing at **DOL Fuels Lab** (Bldg 7137)

**Step 3** Fuels lab will issue a GO/NO GO on the test; Bring test results to **DPW Environmental Division Hazmat**

**Step 4** Coordinate with **DPW Environmental Division Hazmat** for further instructions on when to bring excess fuel to the PPOC.



### GENERAL INFORMATION

For more information on recycling JP8, contact **PPOC Services**. See protocol sheet A-35 for small quantities of JP8.