

DEPARTMENT OF THE ARMY
HEADQUARTERS, 101ST AIRBORNE DIVISION (AIR ASSAULT) AND FORT CAMPBELL
2700 Indiana Avenue
Fort Campbell, Kentucky 42223-5656
15 August 2011

Facilities Engineering

Quality Assurance (Electrical) Inspection Standards

Contents (listed by section and page number)

Purpose • 1, *Page 1*
References • 2, *Page 1*
Terminology and types of inspections • 3, *Page 1*
Cam Regulation Applies • 4, *Page 2*
Cam Regulation Does Not Apply • 5, *Page 2*
Ft. Campbell Electrical Review Board • 6, *Page 2*
Duties of Electrical Review Board • 7, *Page 3*
Electrical Review Board Procedure • 8, *Page 3*
Policy • 9, *Page 3*
Design and Specification Review • 10, *Page 4*
Fort Campbell Electrical Inspectors Qualifications and Duties • 11, *Page 4*
Electrical Permit Application Policy and Procedure • 12, *Page 5*
Electrical Inspection Policy and Procedure • 13, *Page 6*
Informal In-Progress Inspection • 14, *Page 7*
Penalties • 15, *Page 7*
Liability of Damages • 16, *Page 7*
Validity • 17, *Page 7*
Repeal of Conflicting Acts • 18, *Page 7*
Records of Permits and Inspections • 19, *Page 7*
Fort Campbell Forms • 20, *Page 8*
Proponent • 21, *Page 8*

Glossary

1. Purpose

This regulation establishes the responsibilities, applicability, policies, and procedures of the Electrical Inspection Program at Fort Campbell, Kentucky. This regulation defines the standards of the practical safe guarding of persons and property from hazards arising from use of electricity.

2. References

- a. AR 420-43 Facilities Engineering Electrical Services
- b. CEGS 01000 Guide Specification, Technical Provisions
- c. FAR 36.507 Federal Acquisition Regulation
- d. National Certification Program for Construction Code Inspectors Candidate Bulletin of Information
- e. NFPA 70L The Model Law Providing for the Inspection of Electrical Inspections
- f. NFPA 70 National Safety Code
- g. NEC National Electric Code
- h. NFPA NESC National Electric Safety Code
- i. RUS Rural Utilities Services Manual

3. Terminology and types of Inspections

- a. AGA-Appropriate Government Agent-Liaison between the Government and the Prime Contractor and/or personnel responsible for installing electrical parts and equipment under an electrical permit at Fort Campbell.
- b. Formal Inspection-The request for a Rough In, Service Release, Final, Pre-Final, Temporary Service, or Follow Up inspection by the Prime Contractor or the AGA.
- c. Informal Inspection-The periodic inspection of electrical parts and equipment during the progress of the

***This regulation supersedes CAM Regulation 420-4 dated 14 May 2010**

installation. Informal inspections may be requested by the AGA.

d. Final Inspection-The inspection of ALL electrical parts and equipment that are completely installed, in place, and ready for use.

e. Partial Final Inspection-Subject to the approval and as determined by the AGA, a portion of electrical parts and equipment that is installed, in place, and ready for use may be inspected for the purpose of beneficial occupancy.

f. Service Release Inspection-The inspection of electrical service equipment, service conductors, associated grounding electrode conductors, and wiring methods associated with the service equipment completely installed, in place, and ready for use PRIOR TO PHYSICAL CONNECTION and ENERGIZING of service conductors to the load side of the supply transformer.

g. Rough In Inspection- The inspection of any electrical parts and equipment installed, in place, and ready for use that is to be hidden from view by the permanent placement of parts of the building or other work including but not limited to underground, concrete slabs, ground rod connections, walls, above ceilings, etc. EXCEPTION-The installation of wiring methods installed in the voids of ongoing construction of block walls where inspections would be impractical.

h. Temporary Service Inspection-The inspection of electrical parts and equipment installed, in place, and ready for use for the purpose of providing temporary electrical power and lighting during the period of construction, remodeling, maintenance, demolition, or similar activities while provisions are being made for permanent power.

i. Follow Up Inspection-The re-inspection of electrical parts and equipment installed for a Rough In, Service Release, Final, Pre-Final, Temporary Service, or Follow Up inspection that were found not to be in conformance with the provisions of this Cam Reg and applicable codes and regulations.

j. Approved Electrical Permit- Installations for which an electrical permit was issued where the Electrical Inspector or parties delegated under Section 7(h) has signed the "approved" line on the electrical permit.

k. Exterior Electrical Distribution-Systems that comprise those parts of an electric power system between the subtransmission system and the primary side of transformers.

l. Interior Electrical Distribution-Electrical parts and equipment on the load side of the service distribution transformer.

4. CAM Regulation Applies to

a. An electrical inspection is required for any new electrical work, modifications, additions or upgrades to existing electrical systems at Fort Campbell.

b. All contractors and/or personnel performing work for all organizations, entities, and tenants at Fort Campbell other than those under Section 5 of this Cam Reg.

c. Installations of conductors and equipment for both interior electrical and exterior electrical distribution that connect to the Fort Campbell electrical network.

d. Installation of raceway, wire way, grounding systems, and the routing of low voltage cable for systems including but not limited to: communications, fire alarm, security, and energy management.

e. Ft. Campbell Family Housing electrical exterior distribution systems that connect to the Ft. Campbell electrical distribution system.

f. Portable power systems for carnivals, special events, and others.

5. CAM Regulation does not apply to

a. Installation in military vehicles, aircraft, railway rolling stocks and automotive vehicles (other than Mobile Homes, and recreational vehicles).

b. Ships and water-craft (other than floating buildings).

c. Installation of railways for generation, transformation, transmission or distribution of power used exclusively for operation of rolling stock or installations used exclusively for railway signaling and communications purposes.

d. Installations, including associated lighting, under the exclusive control of the Directorate of Public Works Exterior Electric Shop for the purpose of communications, metering, generation, control, transformation, transmission or distribution of electric energy. Such installations shall be located in buildings used exclusively by public utilities for such purposes; outdoors on property owned or leased by the utility; on – along public highways, streets, roads, etc.; or outdoors on private property by established rights such as easements. Installations of underground mines and self-propelled mobile surface mining machinery and its attendant electrical trailing cable. Fort Campbell Family Housing assets and privatized interior electrical systems not owned by the Army.

6. Fort Campbell Electrical Review Board

There is hereby created an ad hoc Fort Campbell Electrical Review Board, hereinafter designated as the "Board". The Board shall consist of the Fort Campbell Director of Public Works or duly appointed representative (i.e. Chief Engineering Division) and the following members:

The Fort Campbell DPW Electrical Maintenance Supervisor.
The Fort Campbell DPW Electrical Engineer.
The Fort Campbell DPW Engineer Design Branch Chief.
The Fort Campbell DPW Maintenance and Operations Supervisor or duly appointed representative
The Fort Campbell Director of Emergency Services or duly appointed representative.
The Corps of Engineers-Resident Engineer or duly appointed representative.
The Fort Campbell DPW Exterior Distribution Maintenance Supervisor
The Fort Campbell DPW Contract Management Branch Chief.
The Fort Campbell Electrical Inspector(s)

7. Duties of the Electrical Review Board

- a. Administer and enforce this CAM Reg.
- b. Establish the qualifications, duties, responsibilities of the Fort Campbell Electrical Inspector(s) and recommend candidates for the position(s).
- c. Establish and periodically review a list of states' electrical license valid on Fort Campbell.
- d. Annually review the license of Electrical Contractors and Electricians operating on Fort Campbell.
- e. Maintain records of all meetings.
- f. Review written appeals to the Board of disputed interpretations of this Cam Reg and/or applicable codes and regulations.
- g. Take such other action as the Board may find necessary for updating and/or carrying out the provision of this CAM Reg to include review of Contractors or Electricians performance and notification to the AGA that a contractor's certification to perform electrical work on Fort Campbell is being revoked.
- h. Fort Campbell Electrical Review Board may delegate inspection authority to the Corps of Engineers (COE) Electrical Engineer for the purpose of inspection of Military Construction Army (MCA), unspecified minor (MCA) or other work specifically stated in delegation authority.

8. Electrical Review Board Procedure

- a. Robert's Rules of Order shall govern the proceedings of all Board meetings.
- b. The Fort Campbell Electrical Inspector(s) shall not be permitted to Chair this Board.
- c. A minimum of three (3) Board members are required to constitute a quorum for the transaction of business. (The Chairman of any meeting of the Board including the temporary Chairman may vote). The Board shall hold such meetings as are necessary to carry out the purposes of this CAM Reg. The Chairman or a majority of the members of the Board shall have the authority to call a meeting of the Board. The Board will meet as needed.
- d. The Fort Campbell Electrical Inspector(s) shall be an ex-officio member and shall not have a vote.
- e. Any person, firm, or corporation may register an appeal with the Board for a review of any decision of the Board or of the Fort Campbell Electrical Inspector(s), provided that such appeal is made in writing within fifteen (15) days after such person, firm, or corporation shall have been notified of such decision by the Fort Campbell Electrical Inspector. Upon receipt of such appeal, said Board shall, if requested by the person making the appeal, hold a public hearing and proceed to determine whether the action of the Board or the Fort Campbell Electrical Inspector complies with this CAM Reg, applicable codes, and regulations. Then within ten (10) business days after receipt of the appeal or after holding the hearing, shall make a decision in accordance with its findings and submit the decision of the Board in writing to the AGA.
- f. Records of meetings of the Board shall be open to the public for inspection at the Fort Campbell DPW during normal business hours.

9. Policy

- a. All installations of electric equipment shall be reasonably safe to persons and property and in conformity with the provisions of this CAM Reg, and all orders, rules or regulations issued by the authority thereof. Conformity of installation of electric equipment with applicable regulations set forth in The National Electric Code (NEC), the National Electrical Safety Code (NESC), and exterior electrical distribution systems constructed according to the Rural Utilities Service Manual specifications shall be prima facie evidence that such installations are reasonably safe to persons and property.

b. If conflicts between the NEC, NESC, and contract specifications arise, the more stringent standards shall prevail.

Ensure contracts for all contractors and/or personnel performing work for all organizations, entities, and tenants at Fort Campbell utilize the CAM Reg as a contract requirement. Any or all references in this CAM Reg to on-site employees installation personnel, or other similar term apply equally to an employee (civilian or military) of the US Government or to a contractor to the US Government

The following clause will be inserted into all contracts pertaining to Fort Campbell electrical installations
“No electric equipment shall be installed within or on any Fort Campbell building, structure, or premises, nor shall any alteration or addition be made in any such existing equipment without first securing an Electrical Permit from the Fort Campbell Electrical Inspector in accordance with Fort Campbell Regulation 420-4, except as provided within this CAM Regulation. Copies of this CAM Regulation and Permits shall be obtained at DPW Contract Management Branch Building 846, Georgia Avenue, Fort Campbell, Kentucky.”

c. Installations of electric equipment by persons holding a valid Journeyman or Master Electrician’s License or contractors with a valid Electrical Contractor’s License, approved by the Fort Campbell Electrical Review Board, shall be prima facie evidence that such installations are reasonably safe to persons and property. Electricians holding a Tennessee Limited Licensed Electrician (LLE) license shall be permitted to perform electrical installations \$25,000.00 dollars and below.

d. The enforcement of the latest edition of the National Electrical Code, the National Electrical Safety Code, and the RUS manual will begin one year after the revision year. (Example: The 2011 NEC will initiate enforcement beginning with contracts issued 1 January 2012 through 31 December 2014) All work will be inspected in accordance with the NEC, NESC, and the RUS Manual in force when the contract is issued, unless specified differently by the contract.

e. Only those Military personnel who meet the qualifications laid out in this document are permitted to perform electrical work on the installation and must be under provision of approved Self-Help Troop Construction Projects.

g. Special Permission: The Director of Public Works may grant exception for the installation of conductors and equipment that are not under the exclusive control of the electric utilities and are used to connect the electric utility supply system to the service entrance conductors of the premises served, provided such installations are outside a building or terminate immediately inside a building wall.

h. When the use of any electrical equipment or its installation shall be found to be dangerous to human life or property, the Electrical Inspector(s) is/are hereby empowered to condemn it and/or cause it to be disconnected from its source of electric supply, except that the service equipment and/or utility service drop and/or service lateral wires shall not be disconnected unless said service equipment, service lateral, and/or utility wires in themselves constitute a hazard to life and/or property. When such equipment or installation has been so condemned and/or disconnected, a notice shall be placed thereon listing the causes for the condemnation and/or disconnection. The Electrical Inspector shall also provide written notice of such condemnation and/or disconnection and the causes therefore shall be given within 24 hours to the AGA. No person shall be authorized to remove the said notice and/or reconnect the electric equipment to its source of electric supply, and/or to use or permit to be used electric power in any such electric equipment until such cause for the condemnation and/or disconnection have been remedied to the satisfaction of the AGA.

10. Design and Specification Review

a. All proposed additions, connections, extensions, alterations, or attachments of electrical conductors and equipment are to be reviewed by the Fort Campbell Electrical Inspector prior to installation.

b. The proponent shall have all proposed plans, drawings, and specifications for addition, connection, extension, alteration, or attachment to Fort Campbell electric conductors and equipment shall be delivered to the following location for review by the Fort Campbell Inspector:

Director of Public Works
Engineer Division –Contract Management Branch
ATTN: Electrical Inspector
Bldg 846, Georgia Avenue
Fort Campbell, KY 42223

c. The Fort Campbell Electrical Inspector shall review all proposals for conformity with the provisions of this CAM Reg, all applicable codes, and regulations and forward written notice of conformity or non-conformity to the person, firm, or corporation making the proposal within ten (10) business days, provided the proponent has provided adequate information and responses.

11. Fort Campbell Electrical Inspectors Qualifications and Duties

a. No person shall be employed as a Fort Campbell Electrical Inspector (formerly referred to as Electrical Inspector) unless he/she has successfully completed all the requirements for certification as a Construction Code Inspectors-Construction Code Inspector Certification Examination for Electrical. At a minimum, this entails successfully completing One and Two Family Dwellings, Electrical: General, and Electrical: Plan Review. In addition to the tests mentioned above, new employees must successfully complete all other requirements that are imposed by Kentucky or Tennessee for certification as Construction Code Inspectors-Construction Code Inspector Certification Examination for Electrical. Each Construction Code Inspector/s must comply with all Electrical

registration requirements of the International Association of Electrical Inspectors or International Code Council, Kentucky, or Tennessee.

b. The Electrical Inspector will have the responsibility for making interpretations of all applicable codes and regulations, for recommending the approval of equipment and materials, and recommend granting special permission contemplated in a number of rules.

c. Electrical Inspector(s) shall have the right, in accordance with (IAW) this CAM Reg, to enter any building or premises during reasonable hours, in discharge of his official duties including the making of any inspections, re-inspections, or test of electric equipment contained therein or its installation.

d. Review and approve all proposed connections, extensions, alterations, or attachments to building wiring system, including planned power interruptions during the planning stage.

e. Review all proposed plans, drawings, and specifications for conformity with provision of this CAM Reg, and all orders, rules and regulations issued by the authority having jurisdiction. If, upon review, any proposal is found not to be fully in conformity with the provision of this CAM Reg and all applicable codes and regulations, the Electrical Inspector shall forward to the person, firm or corporation making the proposal a written notice stating the non-conformity of the said proposal within (10) business days.

f. Validate electrical licenses and maintain list of licensed Electrical Contractors and Firms for review by the Board.

g. Process and issue electrical permits and log permit information to the Fort Campbell Electrical Permit Log.

h. Perform duties necessary in carrying out the provisions of this Cam Reg. (Sections 12-14)

12. Electrical Permit Application Policy and Procedure

a. An approved Electrical Contractor's license is required for any person, firm or corporation requiring an Electrical Permit. At minimum, but not limited to, a current valid state Electrical Contractors License is required to obtain and maintain approval.

b. Electricians holding a Tennessee Limited Licensed Electrician (LLE) license shall be permitted to perform electrical installations \$25,000.00 dollars and below.

c. A photocopy of the person, firm, or corporation's license along with photo identification is required to be on file at the DPW Contract Management Branch prior to applying for an electrical permit.

d. No electric equipment shall be installed within or on any Fort Campbell building, structure, or premises, nor shall any alteration or addition be made in any such existing equipment without first securing an Electrical Permit from the Electrical Inspector in accordance with Fort Campbell Regulation 420-4, except as provided within this CAM Regulation. Copies of this CAM Regulation and Permits shall be obtained at DPW Contract Management Branch Building 846, Georgia Avenue, Fort Campbell, Kentucky.

e. A single Electrical Permit is acceptable for Rough In, Service Release, Final, Pre-Final or Follow Up inspections. (for definitions see Section 3)

f. A permit is required for each building where electrical installations are performed at multiple buildings under the same contract and/or project number.

g. Where multiple electrical contractors/firms are performing electrical installations for the same prime contractor each sub-contractor shall be required to obtain a permit to cover his portion of the contract.

h. The Temporary Service Electrical Permit [for definition see Section 3(h)] must be applied for separately

i. The Exterior Electrical Distribution Permit [for definition see Section 3(k)] must be applied for separately.

j. The Electrical Contractor/Firm will need to provide to the Electrical Inspector the following information before a permit can be processed and issued:

k. Building Number (Preferred if available) or Address

l. Prime Contractor's name and phone number

m. Electrical Contractor/Firm's name and phone number

n. Electrical License Number

o. Contract Type

p. Contract Number

q. Project Number

r. Service Size (If applicable provide the amperage, voltage, and phase.)

s. Contracting Officer's Representative (COR) or AGA and phone number

t. Only individuals whose name is on the electrical license can apply for an electrical permit. A formal letter from the licensee listing the names of those that have permission to apply for a permit on their behalf will be accepted.

u. Requests for permits must be made either in person or by telephone Mon-Fri 0730-0830 Building 846. Electronic requests via e-mail may be submitted in lieu of walk in or telephone requests. Email address may be obtained by calling 798-5514 the Contract Management Branch Admin office.

- u. The Electrical Inspector will process the permit request by assigning a permit number, enter the information to the Fort Campbell Electrical Permit Log, and issue processed permit to the Electrical Contractor/Firm and the AGA.
- v. The Electrical Permit shall be conspicuously posted on or near the electrical installation or be readily available if requested by the Electrical Inspector, Safety Inspector, Military Police, or other authorities. The electrical permit must be provided upon request.

13. Electrical Inspection Policy and Procedure

- a. Upon completion of any installation of electric equipment which has been made under permit, it shall be the duty of the person, firm, or corporation making the installation, hereinafter designated as the "Installer" (Prime Contractor) notify the Electrical Inspector to request a Formal Electrical Inspection(s) [for definition see Section 3(b)]. The Electrical Inspector will inspect the work within three (3) business days. The AGA may notify the Electrical Inspector to request an electrical inspection.
- b. The sub-contractor may make request for inspections provided that a formal letter from the Prime Contractor is submitted and approved by the AGA.
- c. You must have available to the Electrical Inspector a company name, permit number, address or building number, type of electrical inspection [for definitions see Section 3], and location within the building or premises when requesting an inspection.
- d. Requests for inspections must be made to the Electrical Inspector who is listed on the permit either in person or by telephone Mon-Fri 0730-0830 Building 846 Electronic requests via e-mail may be submitted in lieu of walk in or telephone requests. E-mail address may be obtained by calling 798-5514 the Contract Mgmt Branch Administration.
- e. When any electrical installation within jurisdiction of the Electrical Inspector is to be hidden from view by the permanent placement of parts of the building or other work, the installer shall request a Rough In Inspection [for definition see Section 3(g)] from the Electrical Inspector or the AGA. The installation shall not be concealed until it has been approved by the AGA. On large installations, where the concealment of equipment proceeds continuously, the Installer shall give the Electrical Inspector or the AGA due notice for each occurrence, minimum of two (2) business days to allow inspections to be made periodically during the progress of the work.
- f. In the event of an emergency or urgent situation where electrical parts are to be hidden from view, the Installer (Prime Contractor) shall notify the AGA immediately prior to proceeding with the installation. The AGA will check the availability of Inspection Services. If no inspector is available then the Contractor will have to make arrangements to protect the work until routine inspection may be scheduled. Under no circumstances shall work proceed without verification and approval from the AGA. If the installer proceeds with the installation without verification and approval, then Section 13(e) of this Reg shall prevail as the standard timeframe for inspection and Fort Campbell will not be held liable for delays for completion of the installation.
- g. Except as otherwise provided in this section, no Installer shall be authorized to make a connection from a supply of electricity or to supply electricity to any electrical service equipment for the installation of which a permit is required, or which has been disconnected or ordered to be disconnected without first requesting a Service Release Inspection [for definition see Section 3(f)] from the Electrical Inspector or the AGA. Service equipment may not be energized until it has been approved by the AGA.
- h. If it is discovered that a connection has been made to an installation which has not been inspected, as outlined in the preceding paragraphs, this information shall immediately be reported to the Electrical Inspector. If, upon subsequent inspection it is found that the installation is not in conformity with the provisions of this CAM Reg, the Electrical Inspector shall notify the AGA to rectify the defects and, if such work is not completed within fifteen (15) days or a longer period which may be specified by the Board, the Board shall have the authority to cause the disconnection of that portion of the installation that is not in conformance. When in the opinion of the Electrical Inspector, there is a danger to human life or property Section 9(h) of this Reg. supersedes this paragraph.
- i. If an installation of electric equipment is located in any territory where the Electrical Inspector has not been authorized to make inspections; subject to other territorial jurisdiction, the supplying agency is authorized to make connections and supply electricity to such installations. Example: Rail road crossing not on Fort Campbell.
- J. Upon completion of the installation of ALL electrical parts and equipment the Prime Contractor or the AGA shall request a Final Inspection [for definition see Section 3(d)] from the Electrical Inspector
- k. A portion of completed work, for the purpose of beneficial occupancy, may be inspected at the request of the AGA. [for definition see Section 3(e)]. The AGA will submit in writing to the Electrical Inspector that portion of completed work that is to be inspected for beneficial occupancy.
- l. Objects, for example, such as desks, chairs, shelves, furniture, etc. shall not be placed in a manner that the Electrical Inspector does not have reasonable clearance for the inspection and/or testing of electrical parts and equipment. Objects that have to be moved for the purpose of inspecting electrical parts and equipment shall be considered as "unreasonable clearance" and the Electrical Inspector, in coordination with the AGA, reserves the

right to abort the inspection.

m. If it is determined that a Formal Inspection has been requested and all electrical parts and equipment are not completed as defined in Sections 3(d)-3(i) of this Reg the Electrical Inspector ,in coordination with the AGA, reserves the right to abort the Formal Inspection until all work is completed in accordance with said sections.

n. If, upon Formal Inspection any installation that is found not to be fully conforming with the provisions of this CAM Reg and all applicable codes and regulations, the Electrical Inspector making the inspection shall forward to the AGA a written Electrical Inspection Deficiency Report stating the deficiencies which have been found to exist.

o. When all deficiencies have been corrected, the installer will request a Follow up Inspection [for definition see section 3(i)] with the Electrical Inspector or the AGA of all corrected deficiencies.

p. If it is determined by the AGA that the items in the deficiency report are not in the Installer's contract, then the AGA will forward back to the Electrical Inspector in writing identifying specifically which items are not in the contract.

q. When all electrical parts and equipment have been installed to the satisfaction of this Cam Reg, then the Electrical Inspector shall forward the Approved Electrical Permit [for definition see Section 3(j)] to the AGA.

r. Contracts for which an electrical permit was issued shall not be closed out without an Approved Electrical Permit.

s. Installations which fail Formal Inspections may be rejected at the discretion of the Inspector and may require a new Permit.

14. Informal In-Progress Inspection

The Fort Campbell Electrical Inspector may visit the job-sites to observe the progress of the installation, monitor the electrical safety of the work-site, and offer suggestions. Coordination with the AGA will occur if any work is found to be out of compliance.

15. Penalties

Any person employed by Fort Campbell who shall willfully violate any of the provisions of this CAM Reg may receive a formal disciplinary action and may be liable for any costs incurred to correct any installations that are not in conformance with the provisions of this CAM Reg.

16. Liability of Damages

This CAM Reg shall not be construed to negate the responsibility or liability of any party owning, operating, controlling, or installing any electric equipment for damages to persons or property caused by any defect therein, nor shall Fort Campbell be held as assuming any such liability by reason of the inspection, re-inspection, or other examination authorized herein, or by reason of the certificate of approval issued as herein provided or disapproval of any equipment authorized herein.

17. Validity

If any section, sub-section, sentence, clause, or phase of this CAM Reg is for any reason held to be unconstitutional, such decision shall not affect the validity of the remaining portion of this CAM Reg.

18. Repeal of Conflicting Acts

All acts or parts of acts in conflict with the provision of this CAM Reg are hereby repealed.

19. Records of Permits and Inspections

DPW shall establish and maintain files that contain copies of all correspondence pertaining to Electrical Inspections. The files will be arranged in permit number sequence ordinal date then by date of violation observed. A Fort Campbell Electrical Permit Log shall be established and maintained that contains a record of all the Electrical Permit(s) issued on Fort Campbell. The contents shall contain, but not be limited to, the following:

- a. Permit Number
- b. Issue Date
- c. Building Number
- d. Prime Contractor and Phone Number
- e. Electrical Contractor and Phone Number
- f. Electrical License Number
- g. Electrical Inspector and Phone Number
- h. Contract Type
- i. Contract Number
- j. Project Number

- k. Contracting Officers Representative/AGA and Phone Number
- l. Service Size

20. FC Forms

Fort Campbell Form 4183, Electrical Permit and Application for Inspection and Fort Campbell Form 4184, Electrical Contractor Registration Form are obsolete in Fort Campbell Regulation 420-4 and are no longer to be used.

21. Proponent

The proponent of this regulation is the Directorate of Public Works (IMSE-CAM-PWO).

JAMES C. McCONVILLE
MG, USA
Commanding

Official:



JEFFREY W. YAEGER
Director, Mission Support Element

DISTRIBUTION:
INTRANET