

FUEL (JP8 LARGE QUANTITIES)

(Fuel Tankers/HEMTT/PODS/Collapsible Drums)

POSSIBLE AREAS OF CONCERN

JP8 is a DOT-flammable material and should be handled in accordance with appropriate safety guidelines.

CHARACTERIZATION

Recycled JP8 can reduce waste of fuel and funds while protecting the environment.

HANDLING PROCEDURES

Step 1 Quantities in excess of 500 gallons require testing at DOL Fuels Lab (Bldg 7137)

Step 2 Fuels lab will issue a GO/NO GO on the test; GO/Pass test will allow the fuel to be used by the unit or coordination with Division G4 to redistribute the fuel for use by other divisional units.

Step 3 NO GO/Fail on test, contact PPOC Services and follow guidance



GENERAL INFORMATION

For more information on recycling JP8, contact PPOC Services. See protocol sheet A-34 for small quantities of JP8.